

# Village of South Blooming Grove

Building Department

P.O. Box 295

Blooming Grove, NY 10914

(845) 782-2600

February 27, 2023

Daniel J, John M, & Daniel C Gilroy  
C/O Susan H. Shapiro  
8 Mangin Rd  
Monroe, NY 10950

To whom it may concern,

This letter is to inform you that your application for a Building Permit for an 8ft high fence at the above mentioned property has been denied by the Building Department. In accordance with Village Zoning Code Section 235-17 C-2, "No fence shall exceed six (6) feet in height, except where located in a front yard, said fence shall not exceed four (4) feet in height." The proposed fence exceeds the height limitations set forth in the Village Code.

You may proceed seeking a variance with the Village's Zoning Board of Appeals.

Should you have any questions, please contact Village Hall at 845-782-2600.

Sincerely,



Wesley Castillo

Building Inspector/Code Enforcement Official - Village of South Blooming Grove  
Fusco Engineering & Land Surveying, P.C.